



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 6-20-09

Code 62.2.5-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title Table E3801.4		Page 676
Proponent Charlie Eldridge	Title Consultant	
Address 551 Grassy Ln., Indianapolis, IN 46217		Phone (317) 370-3444
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>The line, labeled "Branch circuits", of the column, labeled "USE", delete "--" and insert "A".</p> <p>Change Note (b) to the table as follows: b. The grounded conductor shall be insulated except where used to supply other buildings on the same premises. Type USE cable shall not be used inside buildings <u>unless it has an acceptable dual marking such as XHHW with USE.</u></p>		
REASON AND FISCAL IMPACT		
<p>There is no reason to prohibit USE from being used for branch circuits where the USE is from outside panelboards to outside equipment.</p> <p>With new construction, the grounded conductor is not permitted to be bare, even to another structure. Also, USE cable with just USE marked on the outside is often taken into a building but it has not passed the vertical flame test. The cable type must be a recognized type such as RHW to go inside a building.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		